



Numaligarh Refinery Limited
Commercial Department

CORRIGENDUM NO. 1 TO NOTICE INVITING TENDER

Date : January 31, 2018

Name of Work : Procurement of Fire Tenders for NRL Refinery site and NRL Siliguri Marketing Terminal site.

Tender no. : OC43000142/JIN dated 18-01-2018

❖ Some technical clarifications against the existing clauses are mentioned below:

Sl. No.	Existing Clause	NRL's Clarification / Corrigendum
1	05. WATER PUMP (i) The water pump with automatic priming device shall be imported GODIVA, UK make or Rosenbauer make. The fire pump shall be CE certified / UL listed.	(i) The water pump with automatic priming device shall be imported GODIVA, UK make or Rosenbauer make. The fire pump shall be EN / CE certified / UL listed. <i>(Other clauses remain unchanged)</i>
2	07. POWER TAKE-OFF FOR WATER PUMP	The P.T.O for the pump will be of Webster, Hale or OMSI make of suitable ratio for rated output of pump & the torque of vehicle. However PTO should be suitable for trouble free operation of the Pump and must be recommended by the Chassis OEM. <i>(Above is for clarification only, no change in the existing tender clause)</i>
3	07. POWER TAKE-OFF FOR WATER PUMP (ii) Switch for engaging the PTO pneumatically / electrically shall be provided in the drivers cabin. PTO switch shall be of the make same as chassis and to be fitted as per instruction from chassis manufacturer.	(ii) Switch for engaging the PTO shall be either pneumatic or Electro-pneumatic, which is to be provided in the drivers cabin. In case of Electro-pneumatic switch, the chassis OEM shall install the switch in the cabin. <i>(Other clauses remain unchanged)</i>
4	09. WATER MONITOR	Please note that the Monitor shall be CE marked or UL listed or FM approved non-aspirating type. Make: Akron or Elkhart or TFT. <i>(Above is for clarification only, no change in the existing tender clause)</i>
5	06. FOAM PROPORTIONING SYSTEM	The proportioner shall be supplied by the pump manufacturer only, i.e. either by GODIVA or by Rosenbauer. <i>(Above is for clarification only, no change in the existing tender clause)</i>
6	V) SPARES TO BE SUPPLIED WITH FIRE TENDER Sl. No. 14. Complete set of consumables for Chassis (Engine Oil, Coolant, Adblue and any other specific lubricant) required for two nos. of servicing of the chassis after delivery at site: 02 Sets	Sl. No. 14. Complete set of consumables for Chassis (Engine Oil, Coolant and any other specific lubricant) : Quantity supplied shall meet 02 (two) time of replacements. For supply of ADBLUE, bidder shall consider the quantity required for running the engine for approximate 10,000 KM.

❖ Bidders (if any) who have already submitted their bids online, may if they wish, revise their bids during this extended period.

All other terms and conditions of the Tender Document remain unchanged.

CGM (Commercial & Legal)
Numaligarh Refinery Limited

CC:

→ NIC e-tender portal <https://eprocure.gov.in/eprocure/app>,

→ NRL website (www.nrl.co.in)