



Numaligarh Refinery Limited
Commercial Department

CORRIGENDUM NO. 1 TO NOTICE INVITING TENDER

Date: May 15, 2017

Name of Work : "Supply of Cooling Tower Composite Drive Shafts at NRL";

Tender no. : OC43000095/AMA

- **All participating bidders**, shall consider the following technical specifications for supply of Cooling Tower Composite Drive Shafts at NRL:

Composite Coupling for Cooling Tower i.e for Item no. 10, 20 & 30 shall CONSISTS OF:

- a) DRIVE SHAFT SPACER-carbon fiber non-metallic tube,
- b) COUPLING HUB BOTH MOTOR & G.B. END- SS material,
- c) FLEXIBLE ELEMENT MOTOR & G.B. END- SS316 material or rubber bushing with connecting bolts, and
- d) COUPLINGS HARDWARE KITS of SS material.

Following documents in addition to all other mentioned in the tender shall be submitted by the party along with the supply:

- Material Test Certificate for all parts of composite drive shaft coupling i.e. TC for Carbon Fiber Spacer, Hubs, Flexible Elements and all hardware.
- Static balancing certificate for all sets pertaining to Item no. 10, 20 & 30 to be submitted.
- COMPLETE ASSEMBLY SHALL BE BALANCED AS PER ISO 1940 Gr. 6.3 OR HIGHER GRADE and certificate to be submitted.

The Bid submission date has been extended till 11:00 AM of 31-05-2017 and technical bid opening date till 01-06-2017 (after 11:00 AM).

All other terms and conditions of the Tender Document remain unchanged.

GM (Commercial & Legal)
Numaligarh Refinery Limited