

## Numaligarh Refinery Limited Commercial Department

## **CORRIGENDUM NO. 1 TO NOTICE INVITING TENDER**

Date: May 18, 2018

Name of Work : Procurement of Gas Detectors.

Tender no. : OC43000152/JIN dated 09.05.2018

- Some minor changes have been done in the technical tender document as below. Bidders are requested to consider the same during submission of bid.
  - 1. Item 00010 of RFQ: 6100027411 Portable Single gas monitor for H2S.
  - Battery Type shall be Rechargeable battery only.
  - Point No. 8. Battery Life shall be read as below:

    "Battery Running Hrs: At least up to 10 hours continuous operations after each recharge"
  - Point no. 20(c) is deleted from the scope.
  - Point no. 20(d) shall be read as <u>"Standard tubing/ Dust Filter / Water Stop/splash guard filters etc. as</u> applicable"
  - 2. Item 00020 of RFQ: 6100027411
    Portable Multi Gas Detector for LEL&O2
  - Battery Type shall be Rechargeable battery only.
  - Point No. 8. Battery Life shall be read as below:
     "Battery Running Hrs: At least up to 10 hours continuous operations after each recharge"
  - Point No. 15 (c): pump is deleted and revised clause shall be read as below: <u>"Sensors, circuitry: Continuous"</u>
  - Point no. 20(c) is deleted from the scope.
  - Point no. 20(d) shall be read as <u>"Standard tubing/ Dust Filter / Water Stop/splash guard filters etc. as applicable"</u>
- Bidders (if any) who have already submitted their bids online, may if they wish, revise their bids during this extended period.

All other terms and conditions of the Tender Document remain unchanged.

CGM (Commercial & Legal)
Numaligarh Refinery Limited