



Ref: COMM/C02/3319

Date: June 13, 2016

CORRIGENDUM NO. 3 TO NOTICE INVITING TENDER

Job ref. : Supply of medium voltage 3 phase squirrel cage induction motor.
Tender no. : OC02000130/MKD dated 06.05.2016

Technical clarification published for information of all concerned:-

Query from 01 intending bidder:- In your tender document RFQ Page no.: 3 of 20 under Inspection & Testing, we are not clear which test you shall witness. Routine or Type Test. OR you shall witness our standard test carried out by manufacturer.

NRL's clarification:- We refer to the clause 3.1 of Inspection and testing "3.1 All the routine tests and other acceptance tests shall be witnessed by the NRL inspector. The vendor shall give NRL at least 4 weeks' notice for sending his representative to carryout final inspection and witness the tests"

All other entries, terms and conditions of the Tender Document and subsequent corrigenda shall remain unchanged.

GM (Commercial & Legal)
Numaligarh Refinery Limited,
Numaligarh, Dist : Golaghat,
Assam – 785 699