



Numaligarh Refinery Limited
Commercial Department

CORRIGENDUM NO. 3 TO NOTICE INVITING TENDER

Date: June 05, 2018

Name of Work: Procurement of Gas Detectors
Tender no.: OC43000152/JIN dated 09.05.2018

- ❖ Some minor changes have been done in the technical specifications as below. Bidders are requested to consider the same during submission of bid.

Item 00020 of RFQ: 6100027411

Portable Multi Gas Detector for LEL&O2

- Point No. 2 (b): Measuring range of Oxygen (% by volume) shall be read as 0- 25 % (full scale 25% minimum). Accordingly bidders shall offer/ supply.
 - Point No.10.c) The offered gas monitor shall be intrinsically safe and shall be suitable for use in Zone 0, Gr. IIC. Requirement of ATEX measurement performance standard and CE directive is not mentioned in the tender. Please comply the requirement of tender document only.
 - Point 17.a) The operating temperature range as per tender is 5 to +50 Deg C
 - Point No.20) Since as per corrigendum 1 under Point No. 15 (c) the scope of pump supply is deleted, supply of accessories like Standard Tubing with Dust Filter / Water Stop and Sample Tubing (aspirated) shall be considered by bidder as applicable for the offered item.
- ❖ Bidders (if any) who have already submitted their bids online, may if they wish, revise their bids within the due date.

All other terms and conditions of the tender remain unchanged.

GM (Commercial) I/C
Numaligarh Refinery Limited