



NUMALIGARH REFINERY LIMITED
COMMERCIAL DEPARTMENT

Ref.: PUR-MKT-1010270

September 10, 2025

CORRIGENDUM NO. 5 TO NOTICE INVITING TENDER

Job Name: Construction of PEB Warehouse at Bonda, Narengi, Guwahati, Assam

Tender No.: PUR1010270/MKD dtd. 04.08.2025

With reference to above NIT, kindly note the following:

The following clarifications are being provided in response to queries raised by intending bidders. These shall be treated as part of the RFP/NIT document: -

SI	Query	NRL's Clarification
1	While going through the BOQ we have found that only fire alarm system qty is given whereas Technical specification calls for Fire Hydrant system also. Even Pump House is also mentioned in the drawing. Please advise the scope of Fire fighting. Also confirm whether to consider Fire Hydrant System or not.	This is to confirm that fire hydrants and fire pump house are not required to be considered. Only fire alarm system is required.

All other terms and conditions of the tender documents and its corrigenda nos. 1, 2A, 2B, 3 & 4 remain unchanged.

For CGM (Commercial)
Numaligarh Refinery Limited

Monikanchan Das
Chief Manager (Commercial)
Numaligarh Refinery Limited
Numaligarh, Dist : Golaghat
Assam – 785 699