

**NUMALIGARH REFINERY LIMITED****(Technical Recommendation)****(For supply of materials , spares)**

Date:05/10/16

Sub: -Supply of Magnetic Type Flow Meters for P&U including supervision in installation

User Department: Instrumentation	Enq. no.OC03000100-ABH
PR 10063629	Dt.04.08.2016
Proprietary (P) / Non Proprietary (NP): NP	No.of bidders:07

Out come of technical evaluation: -

SI No	Name of Bidder	Technically Acceptability of offers (Technical bid evaluation of Key Parameters to be attached wherever required)		Remarks / Reason for technical rejection
		Technically Acceptable	Item SI. No. as per enquiry	
1	ELECTROSMART	Yes		
		No	10,20,30	PQC 4 b (EIL approval not complied).
2	Emerson Process Management India pvt Limited	Yes	10,20,30	
		No		
3	Endress and Hauser (India) Private Limited	Yes	10,20,30	
		No		
4	J.J. ELECTRICAL CORPORATION	Yes		
		No	10,20,30	PQC (EIL approval and OEM Authorisation) not complied.Make and Model no. not provided
5	Krohne Marshall Pvt Ltd	Yes	10,20,30	
		No		
6	Panumax Enterprise	Yes		
		No	10,20,30	PQC 4 b (EIL approval not complied). Instrument not support HART protocol. Transmitter/Local Indicator are not remote mounted
7	YOKOGAWA INDIA LIMITED	Yes	10,20,30	
		No		

* Reasons of technical rejection to be clearly indicated. Separate sheet, if required, to be enclosed.

Special Note to Commercial (if any):

All the participating qualified bidders have been brought at par in technical specifications as per indent:

Indentor (s) (Signature, name, designation):	Recommended by (Signature, name, designation):
B Dewan DM (Inst.)	S Gogoi M (Inst.)
Approved as per DOA clause 10:	
SM(Inst.)	SM(MP) CM(MP) CM(EM)

Note: - Strike out the line/ space which is not applicable or not required.

